




Test Report No.:	28212426 001		Page 1 of 21	
Client:	Elpumps kft. 4900, Fehérgyarmat, Vasvári P. u. 65, Hungary			
Manufacturer:	Elpumps kft. 4900, Fehérgyarmat, Vasvári P. u. 65, Hungary			
Test item:	Household waterworks			
Identification:	JPV900; JPV1300; JPV1300B; JPV1300 INOX; JPV1500; JPV1500B; VB25/900; VB25/1300; VB25/1300B; VB25/1300 INOX; VB25/1500; VB 25/1500B; VB50/1300; VB50/1500; VP300; BP10; BP14; BP1/4; BP18/3; BP22/3;	Serial No.:	000335/2011	
Receipt No.:	93329446	Date of receipt:	2011-08-22	
Testing location:	TÜV Rheinland InterCert Kft. H-1135 Budapest, Béke utca 43., Hungary			
Test specification:	EN 61000-6-3:2007+A1:2011 EN 55014-1:2006+A1:2009 EN 61000-3-2:2006+A1:2009+A1:2009 EN 61000-3-3:2008 EN 55014-2:1997+A1:2001+A2:2008			
Test result:	The test item passed the test specification(s).			
Testing laboratory	TÜV Rheinland InterCert Kft. H-1132 Budapest, Váci út 48/A-B., Hungary			
Tested by:	Reviewed by:			
2011-08-30	János Horváth		2011-08-30	Imre Király
2011-08-30	Tamás Novotny			
Date	Name	Signature	Date	Name
				Signature
Other Aspects:	Place of manufacture: Elpumps kft. 4900, Fehérgyarmat, Vasvári P. u. 65, Hungary Rated data: 230V, 50Hz, 300..1600W (varies with type)			
Abbreviations:	P(ass) = passed F(ail) = failed N/A = not applicable N/T = not tested			
This test report relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any safety mark on this or similar products.				

Note(s):

The equipment under test is a water pump that serves for private use in a house and garden. The unit is suitable for watering of gardens and lands, and household water supply. The pump is equipped with a pressure switch, that switches the pump off in case the pressure is high. During the tests, the suction pipe was fitted with a foot valve, the pressure pipe was fitted with a stopcock.

The tested appliance doesn't contain any electronic control circuitry, so the appliance is deemed to fulfil the immunity requirements of EN 55014-2:1997+A1:2001+A2:2008 without testing.

The emission tests were conducted according to EN 55014-1:2006+A1:2009, but an additional radiated disturbance test was also conducted, in order to fully comply with the requirements of EN 61000-6-3:2007+A1:2011.

The family consists of the types listed on page 1., the listed types are equal to the tested type regarding EMC aspects. The main difference that affects EMC test results is the rated power, the type VB25/1500 was tested, that has the highest power rating.

Photo of the appliance:



Photos of rated plates:



Contents:

Radio-frequency disturbances of household and similar appliances.....	5
Harmonic current.....	13
Voltage fluctuations and flicker	17

We draw the kind attention of the Applicant (manufacturer) to that according to Clause 4 of standard EN 61000-3-11:2000 (Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems - Equipment with rated current ≤ 75 A and subject to conditional connection):

„If equipment complies with the requirements of EN 61000-3-3 and therefore is not subject to conditional connection, it may be declared so by the manufacturer in documentation made available to users before purchase.

Equipment which does not meet the limits of EN 61000-3-3, when tested or evaluated with reference impedance Z_{ref} , is subject to conditional connection, and the manufacturer shall either:

a.) determine the maximum permissible system impedance Z_{max} at the interface point of the user's supply in accordance with 6.2, declare Z_{max} in the equipment instruction manual and instruct the user to determine in consultation with the supply authority, if necessary, that the equipment is connected only to a supply of that impedance or less, or

b.) test the equipment in accordance with 6.3 and declare in the equipment instruction manual that the equipment is intended for use only in premises having a service current capacity ≥ 100 A per phase, supplied from a distribution network having a nominal voltage of 400/230 V, and instruct the user to determine in consultation with the supply authority, if necessary, that the service current capacity at the interface point is sufficient for the equipment.

The equipment shall be clearly marked as being suitable for use only in premises having a service current capacity equal to or greater than 100 A per phase.

NOTE1 In the case of option a), restrictions to connection may be imposed by the supply authority on the use of equipment if the actual system impedance at the interface point on the user's premises, Z_{act} , exceeds Z_{max} .

NOTE2 In the case of option b) a new symbol (IEC 60417-5855) is under consideration for the purpose of marking equipment.

NOTE3 For options a) and b), if the supply capacity and/or the actual system impedance Z_{act} have been declared to, or measured by, the user, this information may be used to assess the suitability of equipment without reference to the supply authority.”

As the equipment does not comply with the requirements of EN 61000-3-3 standard, therefore we specify the Z_{max} supply network impedance to which the tested appliance may be connected (see page 20.).

Measurement ref. No.: 28212426 001	Standard applied: EN 55014-1:2006+A1:2009 Radio-frequency disturbances of household and similar appliances
---------------------------------------	---

Measurement of disturbance voltage in the frequency range between 150 kHz and 30 MHz

Description of operating conditions applied for testing of the product (settings, load, program, etc.): *The measurement was performed in normal operation mode.*

Test point: *AC power port – mains connection, pole N.*


Disturbance voltage diagram

```

TUV Rheinland InterCert MEEI Division.
Disturbance voltage.                               29. Aug 11 16:07
EUT:        VB25/1500.
Manuf:      Elpumps Kft.
Op Cond:    R&S, ESCS30 No: 836858/003+ESH322+ESH2-25.
Operator:   Novotny Tamas.
Test Spec:  EN 55014-1.
            230 V, 50 Hz. Pole N.
File name:  VB_N.RES
    
```

```

Scan Settings (1 Range)
|----- Frequencies -----|----- Receiver Settings -----|
Start      Stop      Step      IF BW  Detector  M-Time  Atten  Preamp
150k      30M      0.8%     9k     QP+AV     50ms   AUTO  LN   ON
Final Measurement: x QP / + AV      Transducer No. Start      Stop      Name
Meas Time: 1 s                      1      9k      30M      ESH322
    
```



Measurement ref. No.: 28212426 001	Standard applied: EN 55014-1:2006+A1:2009 Radio-frequency disturbances of household and similar appliances
---------------------------------------	---

Measurement of disturbance voltage in the frequency range between 150 kHz and 30 MHz

Description of operating conditions applied for testing of the product (settings, load, program, etc.): *The measurement was performed in normal operation mode.*


Test point: *AC power port – mains connection, pole L.*

Disturbance voltage diagram

```

TUV Rheinland InterCert MEEI Division.
Disturbance voltage.                               29. Aug 11 16:18
EUT: VB25/1500.
Manuf: Elpumps Kft.
Op Cond: R&S, ESCS30 No: 836858/003+ESH3Z2+ESH2-Z5.
Operator: Novotny Tamas.
Test Spec: EN 55014-1.
          230 V, 50 Hz. Pole L.
File name: VB_K.RES

Scan Settings (1 Range)
|----- Frequencies -----| |----- Receiver Settings -----|
Start   Stop      Step   IF BW  Detector M-Time  Atten  Preamp
150k    30M        0.8%  9k     QP+AV    50ms  AUTO  LN   ON
Final Measurement: x QP / + AV      Transducer No. Start   Stop   Name
                      Meas Time: 1 s          1     9k    30M   ESH3Z2
    
```



Measurement ref. No.: 28212426 001	Standard applied: EN 55014-1:2006+A1:2009 Radio-frequency disturbances of household and similar appliances
---------------------------------------	---

Measurement of disturbance power in the frequency range between 30 MHz and 300 MHz

Description of operating conditions applied for testing of the product (settings, load, program, etc.): *The measurement was performed in normal operation mode.*

Test point: *AC power port – mains connection.*


Disturbance power diagram

TUV Rheinland InterCert MEEI Division.
Disturbance power.
EUT: VB25/1500.
Manuf: Elpumps Kft.
Op Cond: R&S, ESCS30 No: 836858/003+MDS21.
Operator: Novotny Tamas.
Test Spec: EN 55014-1.
230 V, 50 Hz.
File name: vb_t.RES

29. Aug 11 15:13

Scan Settings (1 Range)

Frequencies			Receiver Settings					
Start	Stop	Step	IF	BW	Detector	M-Time	Atten	Preamp
30M	300M	1M	120k		QP+AV	50ms	AUTO	LN ON
Final Measurement: x QP / + AV			Transducer No. 7		Start 30M	Stop 300M	Name MDS21	
Meas Time: 1 s								



Measurement ref. No.: 28212426 001	Standard applied: EN 55014-1:2006+A1:2009 Radio-frequency disturbances of household and similar appliances
---------------------------------------	---

Test instruments used:

Denomination	Manufacturer	Type	Serial No.	Next calibration	Applied
Semi anechoic chamber	T-Network	3, 10 m	---	2011-11	<input checked="" type="checkbox"/>
Shielded cabinet	Siepel	3,5x3,5x2,4m	92155	---	<input checked="" type="checkbox"/>
Measuring receiver	R & S	ESCS30	836858/003	2011-09	<input checked="" type="checkbox"/>
Measuring receiver	R & S	ESVS30	826638/014	2012-05	<input checked="" type="checkbox"/>
Measuring receiver	R & S	ESHS30	828144/007	2011-08	<input checked="" type="checkbox"/>
Discontinuous interference analyser	Chase	DIA 1512	5032	2011-10	<input checked="" type="checkbox"/>
Artificial mains network	R & S	ESH2-Z5	828075/008	2013-04	<input checked="" type="checkbox"/>
Pulse limiter	R & S	ESH3-Z2	-	2013-01	<input checked="" type="checkbox"/>
Biconilog antenna	ETS-Lindgren	3142 c	00035886	2012-06	<input checked="" type="checkbox"/>
Absorbing clamp	R & S	MDS21	827643/018	2013-04	<input checked="" type="checkbox"/>
RFI power measuring table	HD	KMS560	560/302	---	<input checked="" type="checkbox"/>
Clamp controller	HD	HD100	100/304	---	<input checked="" type="checkbox"/>

Note(s): ---

Photo(s) on the measuring arrangement:



Measurement of disturbance voltage

<p>Measurement ref. No.:</p> <p style="text-align: center;">28212426 001</p>	<p>Standard applied:</p> <p style="text-align: center;">EN 55014-1:2006+A1:2009</p> <p style="text-align: center;">Radio-frequency disturbances of household and similar appliances</p>
--	--

Photo(s) on the measuring arrangement:




Measurement of disturbance power



Measurement of discontinuous disturbances



Measurement of radiated disturbances



Measurement ref. No.: 28212426 001	Standard applied: EN 61000-3-2:2006+A1:2009+A2:2009 Harmonic current
Date of measurement:	2011-08-29
Ambient conditions:	
Ambient temperature:	28 °C
Relative humidity:	30-60 %
Air pressure	1017 hPa
Test setup:	
Laboratory test <input checked="" type="checkbox"/>	Post-installation test <input type="checkbox"/>
Classification:	A
Calculated measurement uncertainty for harmonic current: $\pm 0.25\%$, $k=2$	
Evaluation based on the test results:	
Passed <input checked="" type="checkbox"/>	Failed <input type="checkbox"/>
Note(s): ---	

Measurement ref. No.: 28212426 001	Standard applied: EN 61000-3-2:2006+A1:2009+A2:2009 Harmonic current
---------------------------------------	---

Operating conditions:

Description of operating conditions applied for testing of the product (settings, load, program, etc.): *The measurement was performed in normal operation mode.*

Classification: *A*

Test point: *AC power port – mains connection.*

Allowed max. values of harmonic current of class „A” equipment:

Harmonic No.	Limit for harmonic current [A]
Odd harmonics	
3	2.30
5	1.14
7	0.77
9	0.40
11	0.33
13	0.21
$15 \leq n \leq 39$	$0.15 \times (15 / n)$
Even harmonics	
2	1.08
4	0.43
6	0.30
$8 \leq n \leq 40$	$0.23 \times (8 / n)$

Note(s): ---

Measurement ref. No.: <p style="text-align: center;">28212426 001</p>	Standard applied: <p style="text-align: center;">EN 61000-3-2:2006+A1:2009+A2:2009</p> <p style="text-align: center;">Harmonic current</p>																																																																																																																																																																																																																																																												
Operating conditions:	Voltage = 229.636 V Voltage Distortion = 0.20 % Current = 4.365 A Current Distortion = 11.90 % Power = 962.178 W Apparent Power = 1002.388 VA CosPhi(1) = 0.967 Power Factor = 0.960 Phase = L1																																																																																																																																																																																																																																																												
Test results:	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Hn</th> <th style="text-align: left;">I rms</th> <th style="text-align: left;">Percentage</th> <th style="text-align: left;">Phase</th> <th style="text-align: left;">Limits</th> <th style="text-align: left;">FAIL</th> </tr> </thead> <tbody> <tr> <td>DC</td> <td>-0.010 A</td> <td>-0.24 %</td> <td>-----</td> <td>no limit</td> <td></td> </tr> <tr> <td>1</td> <td>4.333 A</td> <td>100.00 %</td> <td>-14.72°</td> <td>no limit</td> <td></td> </tr> <tr> <td>2</td> <td>0.006 A</td> <td>0.15 %</td> <td>+115.50°</td> <td>1.080 A</td> <td></td> </tr> <tr> <td>3</td> <td>0.494 A</td> <td>11.40 %</td> <td>+153.08°</td> <td>2.300 A</td> <td></td> </tr> <tr> <td>4</td> <td>0.007 A</td> <td>0.17 %</td> <td>+17.00°</td> <td>0.430 A</td> <td></td> </tr> <tr> <td>5</td> <td>0.145 A</td> <td>3.35 %</td> <td>+144.42°</td> <td>1.140 A</td> <td></td> </tr> <tr> <td>6</td> <td>0.008 A</td> <td>0.18 %</td> <td>-35.59°</td> <td>0.300 A</td> <td></td> </tr> <tr> <td>7</td> <td>0.025 A</td> <td>0.58 %</td> <td>-56.78°</td> <td>0.770 A</td> <td></td> </tr> <tr> <td>8</td> <td>0.004 A</td> <td>0.09 %</td> <td>-58.15°</td> <td>0.230 A</td> <td></td> </tr> <tr> <td>9</td> <td>0.006 A</td> <td>0.14 %</td> <td>-62.10°</td> <td>0.400 A</td> <td></td> </tr> <tr> <td>10</td> <td>0.003 A</td> <td>0.07 %</td> <td>-101.27°</td> <td>0.184 A</td> <td></td> </tr> <tr> <td>11</td> <td>0.007 A</td> <td>0.17 %</td> <td>+160.53°</td> <td>0.330 A</td> <td></td> </tr> <tr> <td>12</td> <td>0.001 A</td> <td>0.03 %</td> <td>-100.97°</td> <td>0.153 A</td> <td></td> </tr> <tr> <td>13</td> <td>0.008 A</td> <td>0.19 %</td> <td>-151.40°</td> <td>0.210 A</td> <td></td> </tr> <tr> <td>14</td> <td>0.002 A</td> <td>0.04 %</td> <td>-179.63°</td> <td>0.131 A</td> <td></td> </tr> <tr> <td>15</td> <td>0.001 A</td> <td>0.01 %</td> <td>-----</td> <td>0.150 A</td> <td></td> </tr> <tr> <td>16</td> <td>0.001 A</td> <td>0.03 %</td> <td>-149.14°</td> <td>0.115 A</td> <td></td> </tr> <tr> <td>17</td> <td>0.003 A</td> <td>0.06 %</td> <td>+115.54°</td> <td>0.132 A</td> <td></td> </tr> <tr> <td>18</td> <td>0.001 A</td> <td>0.02 %</td> <td>-----</td> <td>0.102 A</td> <td></td> </tr> <tr> <td>19</td> <td>0.001 A</td> <td>0.02 %</td> <td>+96.91°</td> <td>0.118 A</td> <td></td> </tr> <tr> <td>20</td> <td>0.004 A</td> <td>0.08 %</td> <td>-170.05°</td> <td>0.092 A</td> <td></td> </tr> <tr> <td>21</td> <td>0.002 A</td> <td>0.05 %</td> <td>+29.70°</td> <td>0.107 A</td> <td></td> </tr> <tr> <td>22</td> <td>0.002 A</td> <td>0.05 %</td> <td>+125.02°</td> <td>0.084 A</td> <td></td> </tr> <tr> <td>23</td> <td>0.000 A</td> <td>0.01 %</td> <td>-----</td> <td>0.098 A</td> <td></td> </tr> <tr> <td>24</td> <td>0.001 A</td> <td>0.02 %</td> <td>-----</td> <td>0.077 A</td> <td></td> </tr> <tr> <td>25</td> <td>0.001 A</td> <td>0.02 %</td> <td>+161.72°</td> <td>0.090 A</td> <td></td> </tr> <tr> <td>26</td> <td>0.001 A</td> <td>0.02 %</td> <td>-----</td> <td>0.071 A</td> <td></td> </tr> <tr> <td>27</td> <td>0.000 A</td> <td>0.00 %</td> <td>-----</td> <td>0.083 A</td> <td></td> </tr> <tr> <td>28</td> <td>0.001 A</td> <td>0.01 %</td> <td>-----</td> <td>0.066 A</td> <td></td> </tr> <tr> <td>29</td> <td>0.001 A</td> <td>0.01 %</td> <td>-----</td> <td>0.078 A</td> <td></td> </tr> <tr> <td>30</td> <td>0.000 A</td> <td>0.01 %</td> <td>-----</td> <td>0.061 A</td> <td></td> </tr> <tr> <td>31</td> <td>0.000 A</td> <td>0.00 %</td> <td>-----</td> <td>0.073 A</td> <td></td> </tr> <tr> <td>32</td> <td>0.000 A</td> <td>0.00 %</td> <td>-----</td> <td>0.058 A</td> <td></td> </tr> <tr> <td>33</td> <td>0.000 A</td> <td>0.01 %</td> <td>-----</td> <td>0.068 A</td> <td></td> </tr> <tr> <td>34</td> <td>0.000 A</td> <td>0.00 %</td> <td>-----</td> <td>0.054 A</td> <td></td> </tr> <tr> <td>35</td> <td>0.000 A</td> <td>0.00 %</td> <td>-----</td> <td>0.064 A</td> <td></td> </tr> <tr> <td>36</td> <td>0.000 A</td> <td>0.01 %</td> <td>-----</td> <td>0.051 A</td> <td></td> </tr> <tr> <td>37</td> <td>0.000 A</td> <td>0.01 %</td> <td>-----</td> <td>0.061 A</td> <td></td> </tr> <tr> <td>38</td> <td>0.000 A</td> <td>0.01 %</td> <td>-----</td> <td>0.048 A</td> <td></td> </tr> <tr> <td>39</td> <td>0.000 A</td> <td>0.00 %</td> <td>-----</td> <td>0.058 A</td> <td></td> </tr> <tr> <td>40</td> <td>0.000 A</td> <td>0.00 %</td> <td>-----</td> <td>0.046 A</td> <td></td> </tr> </tbody> </table>	Hn	I rms	Percentage	Phase	Limits	FAIL	DC	-0.010 A	-0.24 %	-----	no limit		1	4.333 A	100.00 %	-14.72°	no limit		2	0.006 A	0.15 %	+115.50°	1.080 A		3	0.494 A	11.40 %	+153.08°	2.300 A		4	0.007 A	0.17 %	+17.00°	0.430 A		5	0.145 A	3.35 %	+144.42°	1.140 A		6	0.008 A	0.18 %	-35.59°	0.300 A		7	0.025 A	0.58 %	-56.78°	0.770 A		8	0.004 A	0.09 %	-58.15°	0.230 A		9	0.006 A	0.14 %	-62.10°	0.400 A		10	0.003 A	0.07 %	-101.27°	0.184 A		11	0.007 A	0.17 %	+160.53°	0.330 A		12	0.001 A	0.03 %	-100.97°	0.153 A		13	0.008 A	0.19 %	-151.40°	0.210 A		14	0.002 A	0.04 %	-179.63°	0.131 A		15	0.001 A	0.01 %	-----	0.150 A		16	0.001 A	0.03 %	-149.14°	0.115 A		17	0.003 A	0.06 %	+115.54°	0.132 A		18	0.001 A	0.02 %	-----	0.102 A		19	0.001 A	0.02 %	+96.91°	0.118 A		20	0.004 A	0.08 %	-170.05°	0.092 A		21	0.002 A	0.05 %	+29.70°	0.107 A		22	0.002 A	0.05 %	+125.02°	0.084 A		23	0.000 A	0.01 %	-----	0.098 A		24	0.001 A	0.02 %	-----	0.077 A		25	0.001 A	0.02 %	+161.72°	0.090 A		26	0.001 A	0.02 %	-----	0.071 A		27	0.000 A	0.00 %	-----	0.083 A		28	0.001 A	0.01 %	-----	0.066 A		29	0.001 A	0.01 %	-----	0.078 A		30	0.000 A	0.01 %	-----	0.061 A		31	0.000 A	0.00 %	-----	0.073 A		32	0.000 A	0.00 %	-----	0.058 A		33	0.000 A	0.01 %	-----	0.068 A		34	0.000 A	0.00 %	-----	0.054 A		35	0.000 A	0.00 %	-----	0.064 A		36	0.000 A	0.01 %	-----	0.051 A		37	0.000 A	0.01 %	-----	0.061 A		38	0.000 A	0.01 %	-----	0.048 A		39	0.000 A	0.00 %	-----	0.058 A		40	0.000 A	0.00 %	-----	0.046 A	
Hn	I rms	Percentage	Phase	Limits	FAIL																																																																																																																																																																																																																																																								
DC	-0.010 A	-0.24 %	-----	no limit																																																																																																																																																																																																																																																									
1	4.333 A	100.00 %	-14.72°	no limit																																																																																																																																																																																																																																																									
2	0.006 A	0.15 %	+115.50°	1.080 A																																																																																																																																																																																																																																																									
3	0.494 A	11.40 %	+153.08°	2.300 A																																																																																																																																																																																																																																																									
4	0.007 A	0.17 %	+17.00°	0.430 A																																																																																																																																																																																																																																																									
5	0.145 A	3.35 %	+144.42°	1.140 A																																																																																																																																																																																																																																																									
6	0.008 A	0.18 %	-35.59°	0.300 A																																																																																																																																																																																																																																																									
7	0.025 A	0.58 %	-56.78°	0.770 A																																																																																																																																																																																																																																																									
8	0.004 A	0.09 %	-58.15°	0.230 A																																																																																																																																																																																																																																																									
9	0.006 A	0.14 %	-62.10°	0.400 A																																																																																																																																																																																																																																																									
10	0.003 A	0.07 %	-101.27°	0.184 A																																																																																																																																																																																																																																																									
11	0.007 A	0.17 %	+160.53°	0.330 A																																																																																																																																																																																																																																																									
12	0.001 A	0.03 %	-100.97°	0.153 A																																																																																																																																																																																																																																																									
13	0.008 A	0.19 %	-151.40°	0.210 A																																																																																																																																																																																																																																																									
14	0.002 A	0.04 %	-179.63°	0.131 A																																																																																																																																																																																																																																																									
15	0.001 A	0.01 %	-----	0.150 A																																																																																																																																																																																																																																																									
16	0.001 A	0.03 %	-149.14°	0.115 A																																																																																																																																																																																																																																																									
17	0.003 A	0.06 %	+115.54°	0.132 A																																																																																																																																																																																																																																																									
18	0.001 A	0.02 %	-----	0.102 A																																																																																																																																																																																																																																																									
19	0.001 A	0.02 %	+96.91°	0.118 A																																																																																																																																																																																																																																																									
20	0.004 A	0.08 %	-170.05°	0.092 A																																																																																																																																																																																																																																																									
21	0.002 A	0.05 %	+29.70°	0.107 A																																																																																																																																																																																																																																																									
22	0.002 A	0.05 %	+125.02°	0.084 A																																																																																																																																																																																																																																																									
23	0.000 A	0.01 %	-----	0.098 A																																																																																																																																																																																																																																																									
24	0.001 A	0.02 %	-----	0.077 A																																																																																																																																																																																																																																																									
25	0.001 A	0.02 %	+161.72°	0.090 A																																																																																																																																																																																																																																																									
26	0.001 A	0.02 %	-----	0.071 A																																																																																																																																																																																																																																																									
27	0.000 A	0.00 %	-----	0.083 A																																																																																																																																																																																																																																																									
28	0.001 A	0.01 %	-----	0.066 A																																																																																																																																																																																																																																																									
29	0.001 A	0.01 %	-----	0.078 A																																																																																																																																																																																																																																																									
30	0.000 A	0.01 %	-----	0.061 A																																																																																																																																																																																																																																																									
31	0.000 A	0.00 %	-----	0.073 A																																																																																																																																																																																																																																																									
32	0.000 A	0.00 %	-----	0.058 A																																																																																																																																																																																																																																																									
33	0.000 A	0.01 %	-----	0.068 A																																																																																																																																																																																																																																																									
34	0.000 A	0.00 %	-----	0.054 A																																																																																																																																																																																																																																																									
35	0.000 A	0.00 %	-----	0.064 A																																																																																																																																																																																																																																																									
36	0.000 A	0.01 %	-----	0.051 A																																																																																																																																																																																																																																																									
37	0.000 A	0.01 %	-----	0.061 A																																																																																																																																																																																																																																																									
38	0.000 A	0.01 %	-----	0.048 A																																																																																																																																																																																																																																																									
39	0.000 A	0.00 %	-----	0.058 A																																																																																																																																																																																																																																																									
40	0.000 A	0.00 %	-----	0.046 A																																																																																																																																																																																																																																																									

Measurement ref. No.: 28212426 001	Standard applied: EN 61000-3-2:2006+A1:2009+A2:2009 Harmonic current
---------------------------------------	---

Test instruments used:

Denomination	Manufacturer	Type	Serial No.	Next calibration	Applied
Digital flickermeter -real time harmonic analyser	PMM	PMM 1000	H90598	2012-05	<input checked="" type="checkbox"/>
Power supply	Kikusui	PCR 2000L	A0000448	*	<input checked="" type="checkbox"/>
Power supply	Kikusui	PCR 2000L	A0000449	*	<input checked="" type="checkbox"/>
Multimeter	Hioki	3257-50	040418901	2011-10	<input checked="" type="checkbox"/>

Additional information:

* The power supplies are not calibrated instruments. Their output parameters are checked during each measurement.

Note(s): ---

Photo(s) on the measuring arrangement:



Measurement ref. No.: 28212426 001	Standard applied: EN 61000-3-3:2008 Voltage fluctuations and flicker
Date of measurement:	2011-08-29
Ambient conditions:	
Ambient temperature:	28 °C
Relative humidity:	30-60 %
Air pressure	1017 hPa
Test setup:	
Laboratory test <input checked="" type="checkbox"/>	Post-installation test <input type="checkbox"/>
Evaluation based on the test results:	
Passed <input checked="" type="checkbox"/>	Failed <input type="checkbox"/>
Note(s): ---	

Measurement ref. No.: 28212426 001	Standard applied: EN 61000-3-3:2008 Voltage fluctuations and flicker
---------------------------------------	---

Operating conditions:

Description of operating conditions applied for testing of the product (settings, load, program, etc.): *The measurement was performed with the pump switched on and off once per minute.*

Test point: *AC power port – mains connection.*

Results of measurement of voltage fluctuations and voltage changes:

Limits	Measured value	Limit value
Value of short term flicker indicator (P_{st})	-	-
Value of long term flicker indicator (P_{lt})	-	-
Time of d(t) during a voltage change for more 3.3 %	<i>200 ms</i>	500 ms
Relative steady-state voltage change d_c	<i>1.337 %</i>	3.3 %
Maximum relative voltage change d_{max}		
a) without additional conditions	<i>5.139 %</i>	3.0 %
b)	-	-
- manual switching		
- automatic switching more frequently twice per day and having a delayed restart		
- manual restart after power supply interruption		
c)	-	-
- is attended whilst in use		
- is switched on automatically or manually no more than twice per day and having a delayed restart, or manual restart after power supply interruption		

Note(s): *Although the equipment is not hand switched, the flicker measurement was performed according to EN 61000-3-3:2008 Annex B, the limits for long term flicker indicator(P_{st}) and long term flicker indicator(P_{lt}) were not taken into account.*

Measurement ref. No.: 28212426 001	Standard applied: EN 61000-3-3:2008 Voltage fluctuations and flicker
---------------------------------------	---

Measured values:

Channel 1 measured values

N	Time	Pmax	Pst	Plt	dt Over	dmax	dc	FAIL
1	10:27	88.56	1.929	0.843	0.160	5.214	1.269	FAIL
2	10:28	88.64	1.940	1.065	0.180	5.198	1.310	FAIL
3	10:29	90.52	1.958	1.224	0.200	5.536	1.337	FAIL
4	10:30	88.98	1.936	1.346	0.200	5.298	1.325	FAIL
5	10:31	88.45	1.919	1.446	0.180	5.427	1.313	FAIL
6	10:32	87.08	1.910	1.534	0.190	5.322	1.318	FAIL
7	10:33	84.85	1.869	1.607	0.170	5.121	1.317	FAIL
8	10:34	86.85	1.916	1.679	0.200	5.425	1.315	FAIL
9	10:35	85.45	1.890	1.749	0.172	5.130	1.311	FAIL
10	10:36	82.65	1.842	1.798	0.160	5.048	1.322	FAIL
11	10:37	86.09	1.892	1.855	0.180	5.420	1.314	FAIL
12	10:38	85.40	1.887	1.743	0.170	5.122	1.311	FAIL
13	10:39	81.60	1.836	1.848	0.150	4.983	1.310	FAIL
14	10:40	84.71	1.874	1.842	0.170	5.289	1.310	FAIL
15	10:41	83.21	1.853	1.832	0.170	5.075	1.288	FAIL
16	10:42	82.32	1.842	1.824	0.170	5.026	1.308	FAIL
17	10:43	80.39	1.828	1.816	0.170	4.956	1.312	FAIL
18	10:44	81.03	1.824	1.808	0.160	5.012	1.312	FAIL
19	10:45	79.95	1.831	1.805	0.170	4.937	1.330	FAIL
20	10:46	81.72	1.841	1.798	0.170	5.057	1.330	FAIL
21	10:47	83.05	1.833	1.794	0.180	5.274	1.314	FAIL
22	10:48	79.78	1.836	1.793	0.160	4.989	1.291	FAIL
23	10:49	78.75	1.809	1.786	0.160	4.884	1.291	FAIL
24	10:50	80.38	1.822	1.836	0.170	4.995	1.296	FAIL
Limits:			no lim.	no lim.	0.500	3.000	3.300	

Channel 2 measured values (Source Check)

N	Time	Pmax	Pst	Plt	dt Over	dmax	dc	FAIL
1	10:27	0.183	0.172	0.075	0.000	0.297	0.010	
2	10:28	0.192	0.172	0.095	0.000	0.291	0.014	
3	10:29	0.202	0.173	0.109	0.000	0.315	0.016	
4	10:30	0.190	0.171	0.119	0.000	0.289	*****	
5	10:31	0.200	0.173	0.129	0.000	0.308	*****	
6	10:32	0.176	0.170	0.136	0.000	0.317	*****	
7	10:33	0.174	0.170	0.143	0.000	0.323	*****	
8	10:34	0.188	0.171	0.150	0.000	0.328	*****	
9	10:35	0.173	0.170	0.156	0.000	0.335	*****	
10	10:36	0.168	0.169	0.161	0.000	0.340	*****	
11	10:37	0.190	0.171	0.166	0.000	0.345	*****	
12	10:38	0.176	0.170	0.136	0.000	0.317	*****	
13	10:39	0.159	0.168	0.166	0.000	0.355	*****	
14	10:40	0.174	0.170	0.166	0.000	0.362	*****	
15	10:41	0.164	0.169	0.166	0.000	0.368	*****	
16	10:42	0.174	0.169	0.165	0.000	0.373	*****	
17	10:43	0.152	0.168	0.165	0.000	0.376	*****	
18	10:44	0.157	0.168	0.165	0.000	0.381	*****	
19	10:45	0.158	0.168	0.165	0.000	0.386	*****	
20	10:46	0.152	0.167	0.164	0.000	0.389	*****	
21	10:47	0.161	0.168	0.164	0.000	0.392	0.165	
22	10:48	0.149	0.167	0.164	0.000	0.276	*****	
23	10:49	0.156	0.168	0.164	0.000	0.282	*****	
24	10:50	0.160	0.168	0.168	0.000	0.287	*****	
Limits:			0.400	no lim.	no lim.	0.2dmax1	no lim.	

Measurement ref. No.: 28212426 001	Standard applied: EN 61000-3-3:2008 Voltage fluctuations and flicker
---------------------------------------	---

As seen from the test results, the equipment does not comply with the requirements of EN 61000-3-3 standard.

According to Sub-Clause 6.2.2 of standard EN 61000-3-11 (Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems - Equipment with rated current ≤ 75 A and subject to conditional connection), in such cases the equipment may only be connected to a supply network having a lower impedance than that specified by EN 61000-3-3 as a reference network for the measurements.

The manufacturer shall determine and declare this Z_{max} impedance in the user's manual of the equipment. The result of our calculation is specified below (taking into account the most unfavourable measured value, $d_{max} = 5.536$):

Z_{ref} according to EN 61000-3-11 clause 6.2.2

$R_a = 0.24 \Omega$, $X_a = 0.15 \Omega$ at 50 Hz;

$R_n = 0.16 \Omega$, $X_n = 0.10 \Omega$ at 50 Hz

$Z_{ref} = 0.472 \Omega$

$Z_{sys1} = Z_{ref} * d_{max}limit / d_{max}$	$0.472 * 3 / 5.536$	0.255 Ω
$Z_{sys2} = Z_{ref} * 0.033 / d_c$	$0.472 * 3.3 / 1.337$	1.164 Ω
$Z_{sys3} = Z_{ref} * (1 / P_{st})^{3/2}$	$0.472 * (1 / P_{st})^{3/2}$	N/A
$Z_{sys4} = Z_{ref} * (0.65 / P_{lt})^{3/2}$	$0.472 * (0.65 / P_{lt})^{3/2}$	N/A
Z_{sys}	Minimum of above	0.255 Ω

The equipment shall be connected to a supply network the impedance of which is equal to or lower than the above calculated value ($Z_{sys} = Z_{max} = 0.255$ Ohm).

Measurement ref. No.: 28212426 001	Standard applied: EN 61000-3-3:2008 Voltage fluctuations and flicker
---------------------------------------	---

Test instruments used:

Denomination	Manufacturer	Type	Serial No.	Next calibration	Applied
Digital flickermeter -real time harmonic analyser	PMM	PMM 1000	H90598	2012-05	<input checked="" type="checkbox"/>
Reference impedance	PMM	PMM 1001	0000J91201	2012-05	<input checked="" type="checkbox"/>
Power supply	Kikusui	PCR 2000L	A0000233	*	<input checked="" type="checkbox"/>
Power supply	Kikusui	PCR 2000L	A0000448	*	<input checked="" type="checkbox"/>
Multimeter	Hioki	3257-50	040418901	2011-10	<input checked="" type="checkbox"/>

Additional information:

* The power supplies are not calibrated instruments. Their output parameters are checked during each measurement.

Note(s): ---

Photo(s) on the measuring arrangement:

